

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM
LISTING SERVICE



LISTING No. 7167-1645:173

Page 1 of 1

CATEGORY: Control Unit (Household)

LISTEE: ADEMCO, DBA Honeywell International Inc.,
2 Corporate Center Drive, Ste 100, Melville, New York 11747
Contact: David Kalmus (516) 921-6704 Ext 1910 Fax (516) 364-6953

DESIGN: Model XL-2T combination household fire and burglary warning system control unit with integral digital alarm communicator. Also suitable for use with other separately listed accessories and devices as indicated in the manufacturer's installation and operating instructions. Each control unit is compatible with models XK-406, XL-4600RM, XL-4600SM, 6615, XK-508, XK-5LC, XK-7LC keypads. Refer to listee's data sheet for detailed product description and operational considerations.

OPTIONS: Refer to listee's data sheet for required/optional accessories. When required, accessories shall be CSFM listed.

RATING: 120 VAC, 12 VAC Secondary, 12 VDC Standby

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number and UL label.

APPROVAL: Listed as household combination fire and burglary alarm control unit for use with separately listed compatible initiating and indicating devices.

This control unit can generate the distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72 2002 Edition. Refer to manufacturer's Installation Manual for details.

NOTE:

1. Fire Alarm Verification Feature (delay of fire alarm) shall NOT be used in California.
2. Burglary and other non-fire functions were not examined.
3. Formerly 7167-0495:118



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 12, 2008**

*Listing Expires **June 30, 2009***

Authorized By: **BEN HO, Chief**
Fire Engineering Division

